



St Edmundsbury
BOROUGH COUNCIL

Development Control Committee

2 March 2017

Committee Update Report

Item 4 – DC/15/2151/OUT – Great Wilsey Park, Little Wratting

1. Page 10 Environment Agency has confirmed the additional information has addressed their earlier objection, subject to conditions relating to a contamination risk assessment, remediation of any contamination found, a scheme for surface water disposal and a restriction on piling or foundation designs using penetrative methods.